


FDV - Grunnklemmeholder, Fjærklemme, WKF4TKG/35

EFA-varenr.:	121001004
EI-nummer:	1274773
Leverandørens varenr.	56.704.4055.0
Type betegnelse:	WKFN 4 TKG/35
GTIN-nr.:	4015573935730
Leverandør:	Wieland Electric GmbH
Sertifikat:	
Etim-klasse:	EC000902 - Rekkeklemme for signalbryting / -måling
Tolltariff:	85369010
Salgsenhet:	Stk
Blokk nr.:	100101



Beskrivelse

Sikring rekkeklemme med fjærkontakt tilkopling for montering på TS 35 , nominelt tverrsnitt 4 mm² , bredde 6 mm , farge grå

Teknisk beskrivelse

FASIS Spring clamp connection 0.13 through 35 mm² Standard DIN rail terminal blocks 1.5 through 35 mm² Duo terminal blocks 1.5 through 4 mm² Multi-tier blocks 1.5 through 4 mm² Function blocks 2.5 through 4 mm² Blocks with pluggable connection 2.5 mm² Initiator/actuator blocks 1.5 mm² Miniature blocks 2.5 mm² Terminal blocks for junction boxes 2.5 through 16 mm² fasis for TS 35 Clearly marking all termination points Flexible and universal connecting Jumpering the terminal blocks on two channels Measuring voltage with an integrated testing facility All Wieland Components which require CE general certification are CE certified, and identified with the CE logo

Technical information The information regarding cross sectional area and connection types pertains to unprepared wires without ferrules. The voltage ratings apply to the terminals in their intended application. When different products are mounted adjacent to each other, the proper isolation distances must be adhered to. If the ground blocks of the taris product family are not used inblock assemblies, but are mounted to the rail as single terminal blocks, end clamps have to be used. A detailed description of technical data, the standards requirements, and the application conditions are available under facts & DATA. ATEX regulation For the use of DIN rail terminal blocks in Ex areas, the regulations of EN 50014 apply , whereas for increased safety EExe the regulations of EN 50019 must be followed. For an approximation of the laws of the EU member states, directive 94/9/EG was created, which is generally known as ATEX 100a and which is the basis for harmonization in this field. ATEX stands for ?atmosphere explosive? while 100a refers to the corresponding article of the EC contract. Directive ATEX 100a applies for protection against dust and gas explosions in all industrial Ex areas and in mining. The testing and certifying institutes named in directive ATEX100a must follow accreditation procedures which are the same all over Europe. In accordance with EN 50014/50019 and ATEX 100a, these certifying institutes write out EC certificates for prototype tests. These prototype test certificates for components together with the corresponding quality system certification of the supplier are required to obtain the so-called ATEX approval. In combination with the Ex mark, the markings of the Wieland terminal blocks have the following meaning: Ex Ident

ETIM-egenskaper

Tilkoblingsbart ledertverrsnitt fintrådet	0,13 - 4
Tilkoblingsbart ledertverrsnitt entrådet	0,13 - 6
Merkespenning	500



Tilkoblingstype 1	Tilkobling med fjærklemme
Tilkoblingstype 2	Tilkobling med fjærklemme
Antall etasjer	1
Antall klemmeposisjoner per nivå	2
Monteringsmetode	DIN-skinne, 35 mm
Materiale i isolasjonskropp	Termoplast
Isolasjonmaterialets flammehemmend	V0
Driftstemperaturområde	-40 - 55
Terminalplate nødvendig	Ja
Farge	Grå
Type slissing	Pluggbar
Type tverrbrudd	Uten
Med Integrert testbuss	Nei

Retur/Deponi

Produktet skal leveres til godkjent avfallsdeponi.